



# THERMEX E9 električni kotao – kompenzacione krive na osnovu spoljne temperature


### Compensation curve (offset =0)



### Compensation curve (offset =30)



### Compensation curve (offset =50)



## Vrednosti spoljne temperature – kompenzacione temperature

Outdoor temperature - compensation temperature list

Outdoor temperature	C01	C02	C03	C04	C05	C06	C07	C08	C09	C10
-20°C	10°C	20	30	40	50	61	71	85	85	85
-19°C	10	20	29	39	49	60	69	85	85	85
-18°C	10	19	29	38	48	58	67	85	85	85
-17°C	9	19	28	37	46	57	66	85	85	85
-16°C	9	18	27	36	45	55	64	83	85	85
-15°C	9	18	26	35	44	53	62	80	85	85
-14°C	9	17	26	34	43	52	60	78	85	85
-13°C	8	17	25	33	41	50	59	76	85	85
-12°C	8	16	24	32	40	49	57	73	85	85
-11°C	8	16	23	31	39	47	55	71	85	85
-10°C	8	15	23	30	38	46	53	69	85	85
-9°C	7	15	22	29	36	44	51	66	85	85
-8°C	7	14	21	28	35	43	50	64	85	85
-7°C	7	14	20	27	34	41	48	62	83	85
-6°C	7	13	20	26	33	40	46	60	79	85
-5°C	6	13	19	25	31	38	44	57	76	85
-4°C	6	12	18	24	30	37	43	55	73	85
-3°C	6	12	17	23	29	35	41	53	70	85
-2°C	6	11	17	22	28	34	39	50	67	85
-1°C	5	11	16	21	26	32	37	48	64	85
0°C	5	10	15	20	25	31	35	46	61	85
1°C	5	10	14	19	24	29	34	44	58	85
2°C	5	9	14	18	23	28	32	41	55	83
3°C	4	9	13	17	21	26	30	39	52	78
4°C	4	8	12	16	20	24	28	37	49	73
5°C	4	8	11	15	19	23	27	34	46	69
6°C	4	7	11	14	18	21	25	32	43	64
7°C	3	7	10	13	16	20	23	30	40	60
8°C	3	6	9	12	15	18	21	28	37	55
9°C	3	6	8	11	14	17	20	25	34	50
10°C	3	5	8	10	13	15	18	23	31	46
11°C	2	5	7	9	11	14	16	21	28	41

